



Power Systems

www.pattencat.com



Patten Industries, Inc.
Construction and Power Solutions Since 1933

Aaron Equipment Company
Attn: Patrick Paden
735 E Green Street
Bensenville, IL 60106

Mr. Patrick Paden,

This letter is to provide you with an overall assessment of the Caterpillar 3512 (Serial Number: CMJ00586 Operating Hours: 188) that my technician inspected on January 25, 2010.

During the inspection we performed the following tasks:

- Performed overall visual inspection of the equipment
- Checked all hoses and connections
- Checked coolant and oil levels
- Connected batteries
- Connected jacket water heaters and observed operation
- Connected external fuel supply and primed fuel system
- Started engine and verified proper voltage and speed
- Observed operation and noted no malfunctions or problems

At this point, it appears the generator-set is in good overall condition and shows no wear and tear beyond what would be expected of normal generator set usage.

If you have any further questions please do not hesitate to contact me.

Thank you,

Ryan Craddock
Field Service Dispatcher
Patten Power Systems
630.516.4473 (phone)
630.982.1737 (fax)
craddockr@pattenpower.com

Grayslake
205 South Route 83
Grayslake, Illinois 60030
847.548.1177
847.548.1166 fax

Oglesby
590 Mayer Street
Oglesby, Illinois 61348
815.883.3336
815.883.8043 fax

Elmhurst
615 W. Lake Street
Elmhurst, Illinois 60126
630.530.2200
630.530.0998 fax
630.530.2218 service fax

Rockford
5055 South Main St.
Rockford, Illinois 61102
815.965.8631
815.965.1179 fax

Hammond
6400 Indianapolis Blvd.
Hammond, IN 46320
219.932.6600 or 773.721.6977
219.932.1121 fax