

Patten



AARON
42297001

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name:	AARON	Date:	12/05/11
Unit Location:	YARD	Work Order #:	0
Unit #:	42297001	Acct. #:	
Manufacturer:	KO	Tech #	1511
Model #:	200ROZD71	Hour Meter Start	245.0
Serial #:	355911	Hour Meter Finish	246.0
Voltage Stability	GOOD	Package Serial #:	D671
Rated KW	200		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	100.3%	100.3%	100.2%	100.2%	#VALUE!	#VALUE!	0.0%	0.0%
KW Meter	200.6	200.6	200.3	200.3	#VALUE!	#VALUE!	0.0	0.0
Engine Speed	1,800	1,800	1,800	1,800	#VALUE!	#VALUE!	0	0
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	485	485	485	485				
Voltmeter L2 - L3	485	485	485	485				
Voltmeter L1 - L3	486	486	486	486				
Ammeter L1	239	239	238	238				
Ammeter L2	239	239	239	239				
Ammeter L3	238	238	238	238				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	48	48	47	47				
Water Temp	178	178	179	179				
Ambient Room Temp	34	34	33	33				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	27.0	27.0	27.0	27.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

T STAT BYPASS TUBE HAS A SMALL HOLE IN IT AND IT IS LEAKING COOLANT DRAINED COOLANT LOWER THAN LEAK.

CUSTOMER SIGNATURE:

Date: December 5, 2011

TECHNICIAN SIGNATURE:

Date: December 5, 2011

Patten



AARON

42297001

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	12/5/11
Unit Location	YARD	Work Order #	0
Unit #	42297001	Acct. #	
Manufacturer	KO	Tech #	1511
Model #	200ROZD71	Hour Meter Start	245.0
Serial #	355911	Hour Meter Finish	246.0
Voltage Stability	GOOD	Package Serial #:	D671
Rated KW	200	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

T STAT BYPASS TUBE HAS A SMALL HOLE IN IT AND IT IS LEAKING COOLANT DRAINED COOLANT LOWER THAN LEAK.