

Patten



AARON

42872002

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181

Customer Name:	AARON	Date:	1/4/2012
Unit Location:	YARD	Work Order #:	
Unit #:	42872002	Acct. #:	48000
Manufacturer:	GENERAC	Tech #	1511
Model #:	FORD OG622YA	Hour Meter Start	0.6
Serial #:	20786232	Hour Meter Finish	1.6
Voltage Stability	GOOD		
Rated KW	100		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.5	0.75	1	1.25	1.5	1.75	2
% of Load	99.0%	99.0%	99.0%	99.0%				
KW Meter	100.0	100.0	100.0	100.0				
Engine Speed	1,800	1,800	1,800	1,800				
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	121	121	121	121				
Voltmeter L2 - L3	N/A	N/A	N/A	N/A				
Voltmeter L1 - L3	121	121	121	121				
Ammeter L1	416	416	415	415				
Ammeter L2	N/A	N/A	N/A	N/A				
Ammeter L3	416	416	416	416				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	75	74	72	72				
Water Temp	195	199	199	199				
AMBIENT ROOM TEMP	35	35	35	35				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	14.0	14.0	14.0	14.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

RAN UN IGT AT 100% FOR 1 HR.

CUSTOMER SIGNATURE: _____

TECHNICIAN SIGNATURE: _____

Patten



AARON

42872002

LOAD AND OPERATION TEST

PAGE 2

**PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181**

Customer Name	AARON	Date	1/4/12
Unit Location	YARD	Work Order #	0
Unit #	42872002	Acct. #	48000
Manufacturer	GENERAC	Tech #	1511
Model #	FORD OG622YA	Hour Meter Start	0.6
Serial #	20786232	Hour Meter Finish	1.6
Voltage Stability	GOOD	0	0
Rated KW	100	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	9	10	11	12	13	14	15	16
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
LUBE OIL PRESSURE								
Water Temp								
AMBIENT ROOM TEMP								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								

COMMENTS AND RECOMMENDATIONS

RAN UN IGT AT 100% FOR 1 HR.