

Patten



AARON

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name: AARON

Date: 12/05/11

Unit Location:

Work Order #:

Unit #:

Acct. #:

Manufacturer: GC

Tech # 1511

Model #: 4914040108

Hour Meter Start 148.0

Serial #: 2081560

Hour Meter Finish 149.0

Voltage Stability GOOD

Package Serial #: N.A

Rated KW 80

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Engine Speed	1,800	1,800	1,800	1,800	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	121	121	121	121				
Voltmeter L2 - L3	N/A	N/A	N/A	N/A				
Voltmeter L1 - L3	121	121	121	121				
Ammeter L1	324	324	324	324				
Ammeter L2	N/A	N/A	N/A	N/A				
Ammeter L3	325	325	325	325				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	46	46	46	46				
Water Temp	198	198	198	198				
Ambient Room Temp	35	35	35	35				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	13.0	13.0	13.0	13.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				
LOAD %	97	97	97	97				
KW Meter	78	78	78	78				

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.

CUSTOMER SIGNATURE:

Date: December 5, 2011

TECHNICIAN SIGNATURE:

Date: December 5, 2011

Patten



AARON

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	12/5/11
Unit Location		Work Order #	
Unit #		Acct. #	
Manufacturer	GC	Tech #	1511
Model #	4914040108	Hour Meter Start	148.0
Serial #	2081560	Hour Meter Finish	149.0
Voltage Stability	GOOD	Package Serial #:	N.A
Rated KW	80	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
LOAD %								
KW Meter								
0								

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.