

Patten



AARON

0

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1

(877) 891-4181 www.pattenpower.com

Customer Name:	AARON	Date:	10/12/11
Unit Location:	0	Work Order #:	0
Unit #:	0	Acct. #:	0
Manufacturer:	CU	Tech #	1511
Model #:	QSK60-G7	Hour Meter Start	206.0
Serial #:	33153518	Hour Meter Finish	208.0
Voltage Stability	GOOD	Package Serial #:	N/A
Rated KW	2000		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	78.8%	79.2%	78.8%	79.2%	78.8%	78.8%	78.8%	78.8%
KW Meter	1,576.4	1,583.7	1,576.4	1,583.7	1,576.4	1,576.4	1,576.4	1,576.4
Engine Speed	1,800	1,800	1,800	1,800	1,800	1,800	1,800	1,800
Power Factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Voltmeter L1 - L2	12700	12700	12700	12700	12700	12700	12700	12700
Voltmeter L2 - L3	12700	12700	12700	12700	12700	12700	12700	12700
Voltmeter L1 - L3	12700	12700	12700	12700	12700	12700	12700	12700
Ammeter L1	74	74	74	74	74	74	74	74
Ammeter L2	69	69	69	69	69	69	69	69
Ammeter L3	72	73	72	73	72	72	72	72
Frequency Meter	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0
Lube Oil Pressure	70	69	69	68	68	68	68	68
Water Temp	184	186	186	187	188	189	189	189
Ambient Room Temp	56	56	56	56	56	57	58	58
Exhaust Temp	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Oil Temp	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Battery Voltage	24.0	24.0	24.0	25.0	25.0	25.0	25.0	25.0
Fuel Pressure	331	331	330	331	329	329	328	328
Fuel Level	85%			65%			45%	

COMMENTS AND RECOMMENDATIONS

LOOKS TO HAVE A BAD ALT. CUSTOMER WANTS ALT REPLACED ON ORDER AND PATTEN WILL INSTALL.

CUSTOMER SIGNATURE:

Date: October 12, 2011

TECHNICIAN SIGNATURE:

Date: October 12, 2011

Patten



AARON

0

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	10/12/11
Unit Location	0	Work Order #	0
Unit #	0	Acct. #	0
Manufacturer	CU	Tech #	1511
Model #	QSK60-G7	Hour Meter Start	206.0
Serial #	33153518	Hour Meter Finish	208.0
Voltage Stability	GOOD	Package Serial #:	N/A
Rated KW	2000	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

LOOKS TO HAVE A BAD ALT. CUSTOMER WANTS ALT REPLACED ON ORDER AND PATTEN WILL INSTALL.