

Patten



Arron Equipment

Portable

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name: Arron Equipment
Unit Location: 0
Unit #: Portable
Manufacturer: AA
Model #: 3412
Serial #: 2WJ1039
Voltage Stability: ok
Rated KW: 800

Date: 02/03/12
Work Order #: EM38334
Acct. #: 0
Tech #: 2626
Hour Meter Start: 261
Hour Meter Finish: 262.0
Package Serial #: 0

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	98.2%	98.2%	98.2%	98.2%	0.0%	0.0%	0.0%	0.0%
KW Meter	785.6	785.6	785.6	785.6	0.0	0.0	0.0	0.0
Engine Speed	1,803	1,803	1,803	1,803	0	0	0	0
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	480	480	480	480				
Voltmeter L2 - L3	480	480	480	480				
Voltmeter L1 - L3	480	480	480	480				
Ammeter L1	945	945	945	945				
Ammeter L2	945	945	945	945				
Ammeter L3	945	945	945	945				
Frequency Meter	60.1	60.1	60.1	60.1				
Lube Oil Pressure	63	62	63	63				
Water Temp	180	180	180	180				
Ambient Room Temp	35	35	35	35				
Exhaust Temp	ok	ok	ok	ok				
Oil Temp	ok	ok	ok	ok				
Battery Voltage	27.0	27.0	27.0	27.0				
Fuel Pressure	45	45	45	45				
Fuel Level								

COMMENTS AND RECOMMENDATIONS

CUSTOMER SIGNATURE: _____ Date: February 3, 2012

TECHNICIAN SIGNATURE: _____ Date: February 3, 2012

Patten



Arron Equipment

Portable

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	Arron Equipment	Date	2/3/12
Unit Location	0	Work Order #	EM38334
Unit #	Portable	Acct. #	0
Manufacturer	AA	Tech #	2626
Model #	3412	Hour Meter Start	261
Serial #	2WJ1039	Hour Meter Finish	262.0
Voltage Stability	ok	Package Serial #:	0
Rated KW	800	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

0

CUSTOMER SIGNATURE: _____ Date: February 3, 2012

TECHNICIAN SIGNATURE: _____ Date: February 3, 2012