

Patten



Aaron Equipment

0

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name:	Aaron Equipment	Date:	02/21/12
Unit Location:	735 E. Green St.	Work Order #:	EM38574
Unit #:	0	Acct. #:	0048000
Manufacturer:	Generac	Tech #	1511
Model #:	FORD	Hour Meter Start	10
Serial #:	WSG1068	Hour Meter Finish	11.0
Voltage Stability	GOOD	Package Serial #:	0
Rated KW	150 kW		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	94.0%	94.0%	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	138.5	94.0	138.5	138.5	0.0	0.0	0.0	0.0
Engine Speed	1,800	94	94	94	0	0	0	0
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	483	483	483	483				
Voltmeter L2 - L3	482	482	482	482				
Voltmeter L1 - L3	483	483	483	483				
Ammeter L1	165	165	165	165				
Ammeter L2	166	166	166	166				
Ammeter L3	166	166	166	166				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	67	65	62	62				
Water Temp	203	204	204	204				
Ambient Room Temp	35	35	35	35				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	13.0	13.0	13.0	13.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

CUSTOMER SIGNATURE: _____

Date: February 21, 2012

TECHNICIAN SIGNATURE: _____

Date: February 21, 2012

Patten



Aaron Equipment

0

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name	Aaron Equipment	Date	2/21/12
Unit Location	735 E. Green St.	Work Order #	EM38574
Unit #	0	Acct. #	0048000
Manufacturer	Generac	Tech #	1511
Model #	FORD	Hour Meter Start	10
Serial #	WSG1068	Hour Meter Finish	11.0
Voltage Stability	GOOD	Package Serial #:	0
Rated KW	150 kW		0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

0

CUSTOMER SIGNATURE: _____

Date: February 21, 2012

TECHNICIAN SIGNATURE: _____

Date: February 21, 2012