

Patten



AARON

YARD

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name: AARON

Date:

06/25/12

Unit Location:

Work Order #:

Unit #: YARD

Acct. #:

Manufacturer: GM

Tech #

1511

Model #: 8.1 L

Hour Meter Start

4.0

Serial #: 8850

Hour Meter Finish

5.0

Voltage Stability GOOD

Package Serial #:

N.A

Rated KW 80

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	96.0%	96.0%	96.0%	96.0%	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	76.8	76.8	76.8	76.8	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Engine Speed	1,800	1,800	1,800	1,800	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	489	489	489	489				
Voltmeter L2 - L3	489	489	489	489				
Voltmeter L1 - L3	489	489	489	489				
Ammeter L1	91	91	91	91				
Ammeter L2	90	90	90	90				
Ammeter L3	91	91	91	91				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	50	48	47	47				
Water Temp	204	206	208	206				
Ambient Room Temp	80	80	80	80				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	13.0	13.0	13.0	13.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.

CUSTOMER SIGNATURE:

Date: June 25, 2012

TECHNICIAN SIGNATURE:

Date: June 25, 2012

Patten



AARON

YARD

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	6/25/12
Unit Location		Work Order #	
Unit #	YARD	Acct. #	
Manufacturer	GM	Tech #	1511
Model #	8.1 L	Hour Meter Start	4.0
Serial #	8850	Hour Meter Finish	5.0
Voltage Stability	GOOD	Package Serial #:	N.A
Rated KW	80	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.