

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name:	AARON	Date:	04/18/12
Unit Location:		Work Order #:	
Unit #:		Acct. #:	
Manufacturer:	JOHN DEERE	Tech #	1511
Model #:	CD6059T16171	Hour Meter Start	292.0
Serial #:	6059TF003	Hour Meter Finish	293.4
Voltage Stability	GOOD	Package Serial #:	N.A
Rated KW	95		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Engine Speed	1,800	1,800	1,800	1,800	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	241	241	241	241				
Voltmeter L2 - L3								
Voltmeter L1 - L3	240	240	240	240				
Ammeter L1	345	345	345	345				
Ammeter L2								
Ammeter L3	344	344	344	344				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	60	60	59	58				
Water Temp	190	191	180	180				
Ambient Room Temp	65	65	65	65				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	14.0	14.0	14.0	14.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				
% OF LOAD	89	89	89	89				
KW METER	83	83	83	83				

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.

CUSTOMER SIGNATURE:

Date: April 18, 2012

TECHNICIAN SIGNATURE:

Date: April 18, 2012

Patten



AARON

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	4/18/12
Unit Location		Work Order #	
Unit #		Acct. #	
Manufacturer	JOHN DEERE	Tech #	1511
Model #	CD6059T16171	Hour Meter Start	292.0
Serial #	6059TF003	Hour Meter Finish	293.4
Voltage Stability	GOOD	Package Serial #:	N.A
Rated KW	95	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
% OF LOAD								
KW METER								
0								

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.