

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
 1 (877) 891-4181 www.pattenpower.com

Customer Name: AARON	Date: 04/19/12
Unit Location:	Work Order #:
Unit #:	Acct. #:
Manufacturer: NEW HOLLAND	Tech # 1511
Model #: 7.5 L	Hour Meter Start 219.0
Serial #: 92461	Hour Meter Finish 220.0
Voltage Stability GOOD	Package Serial #: N.A
Rated KW 180	

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	100.1%	100.1%	100.1%	100.1%	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	180.3	180.3	180.3	180.3	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Engine Speed	1,800	1,797	1,800	1,797	#VALUE!	#VALUE!	#VALUE!	#VALUE!
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	480	480	480	480				
Voltmeter L2 - L3	481	481	481	481				
Voltmeter L1 - L3	480	480	480	480				
Ammeter L1	216	216	216	216				
Ammeter L2	218	218	218	218				
Ammeter L3	216	216	216	216				
Frequency Meter	60.0	59.9	60.0	59.9				
Lube Oil Pressure	50	49	48	48				
Water Temp	190	195	196	196				
Ambient Room Temp	70	70	70	70				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	14.0	14.0	14.0	14.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.

CUSTOMER SIGNATURE: _____ Date: April 19, 2012

TECHNICIAN SIGNATURE: _____ Date: April 19, 2012

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
 1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	4/19/12
Unit Location		Work Order #	
Unit #		Acct. #	
Manufacturer	NEW HOLLAND	Tech #	1511
Model #	7.5 L	Hour Meter Start	219.0
Serial #	92461	Hour Meter Finish	220.0
Voltage Stability	GOOD	Package Serial #:	N.A
Rated KW	180	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT 100% for 1 hr no problems found.