

Patten



AARON

0

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name: AARON
Unit Location: 0
Unit #: 0
Manufacturer: AA
Model #: 3412
Serial #: 81Z14625
Voltage Stability: GOOD
Rated KW: 455 PRIME

Date: 07/10/12
Work Order #: 0
Acct. #: 0
Tech #: 1511
Hour Meter Start: 575.0
Hour Meter Finish: 576.0
Package Serial #: N/A

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	452.8	452.8	452.8	452.8	0.0	0.0	0.0	0.0
Engine Speed	1,800	1,800	1,800	1,800	0	0	0	0
Power Factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Voltmeter L1 - L2	480	480	480	480				
Voltmeter L2 - L3	480	480	480	480				
Voltmeter L1 - L3	480	480	480	480				
Ammeter L1	545	545	545	545				
Ammeter L2	544	544	544	544				
Ammeter L3	545	545	545	545				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	72	72	71	70				
Water Temp	192	192	193	194				
Ambient Room Temp	86	86	86	86				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	27.0	27.0	27.0	27.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

UNIT HAS DATA LINK PROBLEM BETWEEN EMCP AND ALARM PANEL. UNIT ALSO NEEDS EXH PIPE AND RAIN CAP PIPE FROM MUFFLER TO RAIN CAP.

CUSTOMER SIGNATURE:

Date: July 10, 2012

TECHNICIAN SIGNATURE:

Date: July 10, 2012

Patten



AARON

0

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	7/10/12
Unit Location	0	Work Order #	0
Unit #	0	Acct. #	0
Manufacturer	AA	Tech #	1511
Model #	3412	Hour Meter Start	575.0
Serial #	81Z14625	Hour Meter Finish	576.0
Voltage Stability	GOOD	Package Serial #:	N/A
Rated KW	455 PRIME	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!	#VALUE!
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

UNIT HAS DATA LINK PROBLEM BETWEEN EMCP AND ALARM PANEL. UNIT ALSO NEEDS EXH PIPE AND RAIN CAP PIPE FROM MUFFLER TO RAIN CAP.