

Patten



AARON

44354003

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name:	AARON	Date:	07/09/12
Unit Location:		Work Order #:	
Unit #:	44354003	Acct. #:	
Manufacturer:	JOHN DEERE	Tech #	1511
Model #:	4024TF270	Hour Meter Start	0
Serial #:	PE4024T11582	Hour Meter Finish	1.0
Voltage Stability	ok	Package Serial #:	D25TDJ4T2 KATO LIGHT
Rated KW	25		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	100.0%	100.0%	100.0%	100.0%	100.0%	0.0%	0.0%	0.0%
KW Meter	25.0	25.0	25.0	25.0	25.0	0.0	0.0	0.0
Engine Speed	1,800	1,800	1,800	1,800	1,800	0	0	0
Power Factor	1.00	1.00	1.00	1.00	1.00			
Voltmeter L1 - L2	241	241	241	241	241			
Voltmeter L2 - L3	241	241	241	241	241			
Voltmeter L1 - L3	N/A	N/A	N/A	N/A	N/A			
Ammeter L1	103	103	103	103	103			
Ammeter L2	102	102	102	102	102			
Ammeter L3	N/A	N/A	N/A	N/A	N/A			
Frequency Meter	60.0	60.0	60.0	60.0	60.0			
Lube Oil Pressure	48	46	46	46	46			
Water Temp	190	190	190	191	191			
Ambient Room Temp	80	80	80	80	80			
Exhaust Temp	N/A	N/A	N/A	N/A	N/A			
Oil Temp	N/A	N/A	N/A	N/A	N/A			
Battery Voltage	14.0	14.0	14.0	14.0	14.0			
Fuel Pressure	N/A	N/A	N/A	N/A	N/A			
Fuel Level								

COMMENTS AND RECOMMENDATIONS

MAG PICK UP WENT BAD IN FIRST 15 MINS OF RUN REPLACED PICK UP AND RAN EXTRA 15 MINS NO OTHER PROBLEMS FOUND.

CUSTOMER SIGNATURE: _____ Date: July 9, 2012

TECHNICIAN SIGNATURE: _____ Date: July 9, 2012

Patten



AARON

44354003

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	7/9/12
Unit Location		Work Order #	
Unit #	44354003	Acct. #	
Manufacturer	JOHN DEERE	Tech #	1511
Model #	4024TF270	Hour Meter Start	0
Serial #	PE4024T11582	Hour Meter Finish	1.0
Voltage Stability	ok	Package Serial #:	D25TDJ4T2 KATO LIGHT
Rated KW	25		0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

MAG PICK UP WENT BAD IN FIRST 15 MINS OF RUN REPLACED PICK UP AND RAN EXTRA 15 MINS NO OTHER PROBLEMS FOUND.

CUSTOMER SIGNATURE: _____ Date: July 9, 2012

TECHNICIAN SIGNATURE: _____ Date: July 9, 2012