

Unit

Serial Number	In-Service Date	Warranty Expiration	Sales Order Number
2139156	04/02/2007	04/02/2008	1002982133
Parts Coverage	Labor Coverage	Travel Coverage	
12 Months / 2000 Hours	12 Months / 2000 Hours	12 Months / 2000 Hours	
Model	Specification Number	Product ID	Material
400REOZDD	GM41981-GA1	Generator Set	400REOZDD
Test Date	Engine Serial Number	Engine Manufacturer Name	Engine Model
02/12/2007	06R0968607	DETROIT DIESEL	6063-HV35
Engine RPM	Fuel Type	KW	KVA
0	Diesel	405	506.00
Amps	Power Factor	Hertz	Phase
608.92	0.80	60	
Low Volt	High Volt	Battery Volt	Market
277	480	24	Industrial
Brand	Usage	Standard Warranty Desc.	Extended Warranty Desc.
Kohler Generator Brand		1 Year Industrial Standby Standard Warranty	
Standard Warranty Part #	Extended Warranty Part #		
GM50088			

Kits

Kit Type	Kit Material Number	Kit Description
Installed	GM35146-MA2	Skid & Plant Mtg.
Installed	GM38859-KA1	Blk Htr,2500W,90/120V,1Ph
Unknown	258811	Power Factor Test,0.8,3Ph
Unknown	343596	Fuel/Water Separator,w/pr
Unknown	333708	Voltage,60Hz,277/480V,Wye
Installed	GM28618-KA4	Run Relay, Dry Contact
Installed	GM35144-MA9	Alternator, 4M4021, Isola
Unknown	334558	LCB,600A,3P,600V,UL,Therm
Installed	GM16993-MA17	Controller,DecMaker550,24
Installed	GM13896-KA3	Radiator Duct Flange
Installed	GM13281-MA3	Air Intake, Standard Duty
Installed	GM52117-KA1	Crankcase Emission Canist
Installed	GM28625-KA8	Coolant in Genset 17 gals
Unknown	343513	Air Cleaner Restrict. Ind
Unknown	279989	Nameplate Rating, Standby
Installed	GM42002-MA1	Control & Harness
Installed	GM41994-MA1	Cooling, Unit Mounted Rad
Installed	GM28621-KA13	Oil in GenSet - 38 qts.
Installed	GM19874-KA1	Decal, UL2200 Listing (Di
Installed	GM38833-KA1	Inner Tank Leak Alarm
Unknown	343478	Flexible Fuel Lines
Installed	GM28618-KA2	Controller Connection
Installed	GM28618-KA5	Failure Relay, Dry Contac

Unit Registrations

Serial #	Type	Submission ID	Service ID	Service Name	Owner Last Name	Owner Company	Registration Date
2139156	Original	0	13225	BAY CITY EQUIPMENT INDUSTRIES,		MITCHELL INTERNATION	03/26/2010