

Patten

**AARON****44398007****LOAD AND OPERATION TEST****PAGE 1**

**PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181**

Customer Name: **AARON**
Unit Location: **YARD**
Unit #: **44398007**
Manufacturer: **Kohler**
Model #: **50REOZJB**
Serial #: **PE4045T656689**
Voltage Stability: **GOOD**
Rated KW: **55**

Date: **8/13/2012**
Work Order #:
Acct. #: **0**
Tech #: **1511**
Hour Meter Start: **1024**
Hour Meter Finish: **1025**

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.5	0.75	1	1.25	1.5	1.75	2
% of Load	100.0%	100.0%	100.0%	100.0%				
KW Meter	50.0	50.0	50.0	50.0				
Engine Speed	1,800	1,800	1,800	1,800				
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	241	241	241	241				
Voltmeter L2 - L3	240	240	240	240				
Voltmeter L1 - L3	n/a	n/a	n/a	n/a				
Ammeter L1	200	200	200	200				
Ammeter L2	200	200	199	199				
Ammeter L3	n/a	n/a	n/a	n/a				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	55	54	54	54				
Water Temp	175	176	176	176				
AMBIENT ROOM TEMP	80	80	80	80				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	13.0	13.0	13.0	13.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

RAN UNIT TO MAX BREAKER LOAD 200 AMPS.

CUSTOMER SIGNATURE: _____

TECHNICIAN SIGNATURE: _____

Patten



AARON

44398007

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181

Customer Name	AARON	Date	8/13/12
Unit Location	YARD	Work Order #	0
Unit #	44398007	Acct. #	0
Manufactor	Kohler	Tech #	1511
Model #	50REOZJB	Hour Meter Start	1024
Serial #	PE4045T656689	Hour Meter Finish	1025
Voltage Stability	GOOD	0	0
Rated KW	55	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	9	10	11	12	13	14	15	16
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
LUBE OIL PRESSURE								
Water Temp								
AMBIENT ROOM TEMP								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								

COMMENTS AND RECOMMENDATIONS

RAN UNIT TO MAX BREAKER LOAD 200 AMPS.