

Patten



AARON

0

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name: AARON
Unit Location: 0
Unit #: 0
Manufacturer: DD
Model #: 12V92
Serial #:
Voltage Stability GOOD
Rated KW 500

Date: 04/12/13
Work Order #: 0
Acct. #: 0
Tech # 1511
Hour Meter Start 695.0
Hour Meter Finish 696.0
Package Serial #: N/A

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	100.1%	100.1%	100.1%	100.1%	0.0%	0.0%	0.0%	0.0%
KW Meter	500.6	500.6	500.6	500.5	0.0	0.0	0.0	0.0
Engine Speed	1,800	1,800	1,800	1,800	0	0	0	0
Power Factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Voltmeter L1 - L2	209	209	209	209				
Voltmeter L2 - L3	209	209	209	209				
Voltmeter L1 - L3	210	210	210	210				
Ammeter L1	1381	1381	1381	1380				
Ammeter L2	1381	1381	1381	1381				
Ammeter L3	1380	1380	1380	1380				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	57	55	54	54				
Water Temp	181	183	184	184				
Ambient Room Temp	40	40	40	40				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	27.0	27.0	27.0	27.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

LOOKED OVER UNIT. CONNECTED LOAD BANK CABLES AND TEST BATTERIES. HOOKED UP FUEL TANK. STARTED UNIT AT 104 DEG. TESTED SHUT DOWNS OK CONTROL PANEL ALARM BOARD LOOKS BAD ALL LIGHTS ARE ON. LOADED UNIT TO 100% FOR 1 HR. DISCONNECTED LOAD BANK BATTERIES AND FUEL SUPPLY. UNIT HAS NO BATTERIES. UNIT HAS BATTERY CHARGER INSTALLED. COOLANT TESTED TO -30 DEG.

CUSTOMER SIGNATURE:

Date: April 12, 2013

TECHNICIAN SIGNATURE:

Date: April 12, 2013

Patten



AARON

0

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	4/12/13
Unit Location	0	Work Order #	0
Unit #	0	Acct. #	0
Manufacturer	DD	Tech #	1511
Model #	12V92	Hour Meter Start	695.0
Serial #		Hour Meter Finish	696.0
Voltage Stability	GOOD	Package Serial #:	N/A
Rated KW	500	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

LOOKED OVER UNIT. CONNECTED LOAD BANK CABLES AND TEST BATTERIES. HOOKED UP FUEL TANK. STARTED UNIT AT 104 DEG. TESTED SHUT DOWNS OK CONTROL PANEL ALARM BOARD LOOKS BAD ALL LIGHTS ARE ON. LOADED UNIT TO 100% FOR 1 HR. DISCONNECTED LOAD BANK BATTERIES AND FUEL SUPPLY. UNIT HAS NO BATTERIES. UNIT HAS BATTERY CHARGER INSTALLED. COOLANT TESTED TO -30 DEG.