

# Patten



**AARON**

**45149001**

**LOAD AND OPERATION TEST**

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 [www.pattenpower.com](http://www.pattenpower.com)

Customer Name: AARON

Date: 06/27/13

Unit Location:

Work Order #: 0

Unit #: 45149001

Acct. #: 0

Manufacturer: FORD

Tech # 1511

Model #: LRG425

Hour Meter Start 134.0

Serial #: 1309583

Hour Meter Finish 135.0

Voltage Stability GOOD

Package Serial #: N/A

Rated KW 20

**MULTIPLE READING TEST**

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	95.9%	95.9%	95.9%	95.9%	0.0%	0.0%	0.0%	0.0%
KW Meter	19.2	19.2	19.2	19.2	0.0	0.0	0.0	0.0
Engine Speed	1,800	1,800	1,800	1,800	0	0	0	0
Power Factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Voltmeter L1 - L2	241	241	241	241				
Voltmeter L2 - L3	240	240	240	240				
Voltmeter L1 - L3	241	241	241	241				
Ammeter L1	46	46	46	46				
Ammeter L2	46	46	46	46				
Ammeter L3	46	46	46	46				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	49	48	47	47				
Water Temp	188	189	190	190				
Ambient Room Temp	60	60	60	60				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	14.0	14.0	14.0	14.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

**COMMENTS AND RECOMMENDATIONS**

HOOKED UP BLOCK HEATER . HOOKED UP GAS LINE. UNIT HAS BATTERY. SET HOOKED GAS PRESSURE. STARTED UNIT AND RAN FOR 1 hr . NO PROBLEMS FOUND. FLAGGED UNIT COMP. CLEANED UP AREA. Unit has no muffler

CUSTOMER SIGNATURE:

Date: June 27, 2013

TECHNICIAN SIGNATURE:

Date: June 27, 2013

# Patten



**AARON**

**45149001**

**LOAD AND OPERATION TEST**

**PAGE 2**

**PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:**  
**1 (877) 891-4181 [www.pattenpower.com](http://www.pattenpower.com)**

Customer Name	AARON	Date	6/27/13
Unit Location		Work Order #	0
Unit #	45149001	Acct. #	0
Manufacturer	FORD	Tech #	1511
Model #	LRG425	Hour Meter Start	134.0
Serial #	1309583	Hour Meter Finish	135.0
Voltage Stability	GOOD	Package Serial #:	N/A
Rated KW	20	0	0

**MULTIPLE READING TEST**

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

**COMMENTS AND RECOMMENDATIONS**

HOOKED UP BLOCK HEATER . HOOKED UP GAS LINE. UNIT HAS BATTERY. SET HOOKED GAS PRESSURE. STARTED UNIT AND RAN FOR 1 hr . NO PROBLEMS FOUND. FLAGGED UNIT COMP. CLEANED UP AREA. Unit has no muffler