

Unit

Serial Number	In-Service Date	Warranty Expiration	Sales Order Number
0747999	05/27/2003	05/27/2004	0003220093
Parts Coverage	Labor Coverage	Travel Coverage	
12 Months / 2000 Hours	12 Months / 2000 Hours	12 Months / 2000 Hours	
Model	Specification Number	Product ID	Material
250RZD	GM16898-GA1	Generator Set	250RZD
Test Date	Engine Serial Number	Engine Manufacturer Name	Engine Model
01/07/2003	06R0720919	DETROIT DIESEL	6063-TKG5
Engine RPM	Fuel Type	KW	KVA
0	Natural	255	319.00
Amps	Power Factor	Hertz	Phase
885.00	0.80	60	
Low Volt	High Volt	Battery Volt	Market
120	208	24	Industrial
Brand	Usage	Standard Warranty Desc.	Extended Warranty Desc.
Kohler Generator Brand	Standby	1 Year Industrial Standby Standard Warranty	
Standard Warranty Part #	Extended Warranty Part #		
GM50088			

Kits

Kit Type	Kit Material Number	Kit Description
Installed	GM18398-MA10	Alternator,4UA13
Unknown	354436	Cooling, Unit Mounted Rad
Unknown	222661	Nameplate Rating, Standby
Unknown	273744	Run Relay, 24V
Unknown	343346	Air Intake, Standard Duty
Installed	GM14225-KA3	Bat,24V,1/650CCA 12V,2/95
Installed	GM19401-KA5	Blk Htr,2500W,90/120V,1Ph
Unknown	333700	Voltage,60Hz,120/208V,Wye
Installed	GM19350-MA3	Control & Harness
Installed	GM17126-MA5	Controller,DecMaker550,24
Unknown	358323	Fuel Code, Natural Gas
Installed	GM19351-KA1	Pre-Alarm Senders, NFPA-1
Unknown	354435	Skid
Unknown	334108	LCB,800-900A,3P,600V,UL,T
Unknown	258811	Power Factor Test,0.8,3Ph

Unit Registrations

Serial #	Type	Submission ID	Service ID	Service Name	Owner Last Name	Owner Company	Registration Date
0747999	Original	0	14690	KINSLEY POWER SYSTEMS		COMCAST	03/26/2010