

Patten

**AARON****45480001****LOAD AND OPERATION TEST**

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:

1 (877) 891-4181 www.pattenpower.com

Customer Name:	AARON	Date:	11/08/13
Unit Location:	0	Work Order #:	0
Unit #:	45480001	Acct. #:	0
Manufacturer:	FORD	Tech #	1511
Model #:	67619-1-03-00	Hour Meter Start	0.0
Serial #:	WSG-1068-6-005-A	Hour Meter Finish	484.0
Voltage Stability	GOOD	Package Serial #:	N/A
Rated KW	60		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	100.2%	100.2%	100.2%	100.2%	#VALUE!	0.0%	0.0%	0.0%
KW Meter	60.1	60.1	60.1	60.1	#VALUE!	0.0	0.0	0.0
Engine Speed	1,800	1,800	1,800	1,800	0	0	0	0
Power Factor	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Voltmeter L1 - L2	208	208	208	208				
Voltmeter L2 - L3	208	208	208	208				
Voltmeter L1 - L3	209	209	209	209				
Ammeter L1	167	167	167	167				
Ammeter L2	166	166	166	166				
Ammeter L3	167	167	167	167				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	72	71	70	70				
Water Temp	179	180	180	180				
Ambient Room Temp	40	40	40	40				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	14.0	14.0	14.0	14.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

ech ID: 1511 -- Friday, November 08, 2013 GGHE-4485352 H000136094 LOOKED OVER UNIT OK
REMOVED OLD CONTROL WIRES. WARMED UNIT J/W HEATER IS WORKING. INSTALLED NEW
CONTROL PANEL SHOCK MOUNTS. HOOKED UP TEST BATTERY . UNIT HAS NO BATTERY. CHECKED
OIL AND COOLANT OK. HOOKED UP LOAD BANK. RAN UNIT AT 100% FOR 1 HR OTHER PRROBLEMS
FOUND.

CUSTOMER SIGNATURE:

Date: November 8, 2013

TECHNICIAN SIGNATURE:

Date: November 8, 2013

Patten



AARON

45480001

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	AARON	Date	11/8/13
Unit Location	0	Work Order #	0
Unit #	45480001	Acct. #	0
Manufacturer	FORD	Tech #	1511
Model #	67619-1-03-00	Hour Meter Start	0.0
Serial #	WSG-1068-6-005-A	Hour Meter Finish	484.0
Voltage Stability	GOOD	Package Serial #:	N/A
Rated KW	60	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

ech ID: 1511 -- Friday, November 08, 2013 GGHE-4485352 H000136094 LOOKED OVER UNIT OK
REMOVED OLD CONTROL WIRES. WARMED UNIT J/W HEATER IS WORKING. INSTALLED NEW
CONTROL PANEL SHOCK MOUNTS. HOOKED UP TEST BATTERY . UNIT HAS NO BATTERY.
CHECKED OIL AND COOLANT OK. HOOKED UP LOAD BANK. RAN UNIT AT 100% FOR 1 HR OTHER
PRROBLEMS FOUND.