

Unit

Serial Number	In-Service Date	Warranty Expiration	Sales Order Number
2039992	06/13/2005	06/13/2010	1001338772
Parts Coverage	Labor Coverage	Travel Coverage	
60 Months / 3000 Hours	60 Months / 3000 Hours	60 Months / 3000 Hours	
Model	Specification Number	Product ID	Material
100REOZJB	GM31029-GA3	Generator Set	100REOZJB
Test Date	Engine Serial Number	Engine Manufacturer Name	Engine Model
04/20/2005	PE6068T444382	JOHN DEERE	6068TF250
Engine RPM	Fuel Type	KW	KVA
0	Diesel	110	138.00
Amps	Power Factor	Hertz	Phase
132.31	1.00	60	
Low Volt	High Volt	Battery Volt	Market
277	480	12	Industrial
Brand	Usage	Standard Warranty Desc.	Extended Warranty Desc.
Kohler Generator Brand	Standby	1 Year Industrial Standby Standard Warranty	5 Year Industrial Extended Comprehensive Warranty
Standard Warranty Part #	Extended Warranty Part #		
GM50088	221887		

Kits

Kit Type	Kit Material Number	Kit Description
Installed	GM39937-MA1	Load Connection Module
Unknown	273743	Run Relay, 12V
Installed	GM33871-KA2	Silencer, Crit. Roof Moun
Unknown	275595	Safeguard Breaker
Installed	GM19874-KA1	Decal, UL2200 Listing (Di
Installed	GM33867-KA2	Enclosure, Weather
Installed	GM17672-MA105	Alternator, 4S9W, WFE
Installed	364502-MA43	Controller,16 Light,Dec3+
Installed	GM20968-KA1	Block Heater, 1500W, 120V
Installed	GM20783-MA1	Air Intake, Standard Duty
Unknown	347274	Failure Relay w/Harness,1
Installed	GM17679-KA3	LCB, 150A,3P, 600V, UL,TH
Installed	GM37533-MA1	Cooling, Unit Mounted Rad
Installed	GM28625-KA2	Coolant in Genset 6 gals.
Unknown	222661	Nameplate Rating, Standby
Installed	GM20880-MA3	Control & Harness, NON DE
Installed	GM19461-KA2	Flexible Fuel Lines
Unknown	333708	Voltage,60Hz,277/480V,Wye
Installed	GM21530-MA2	Skid, 41"
Installed	GM20938-KA2	Pre-Alarm Senders, NFPA-1
Installed	GM28569-KA1	Battery Charger,Float/Equ

Unit Registrations

Serial #	Type	Submission ID	Service ID	Service Name	Owner Last Name	Owner Company	Registration Date
2039992	Original	0	11639	FIDELITY POWER SYSTEMS		WGAA	03/26/2010