

Unit

Serial Number	In-Service Date	Warranty Expiration	Sales Order Number
2027551	03/28/2005	03/28/2006	1000538034
Parts Coverage	Labor Coverage	Travel Coverage	
12 Months / 2000 Hours	12 Months / 2000 Hours	12 Months / 2000 Hours	
Model	Specification Number	Product ID	Material
1350DSEB	GM34995-GA1S	Generator Set	1350DSEB
Test Date	Engine Serial Number	Engine Manufacturer Name	Engine Model
06/21/2005	5262001719	DETROIT DIESEL	T123-7M36
Engine RPM	Fuel Type	KW	KVA
0	Diesel	1360	1700.00
Amps	Power Factor	Hertz	Phase
2045.00	0.80	60	
Low Volt	High Volt	Battery Volt	Market
277	480	24	Industrial
Brand	Usage	Standard Warranty Desc.	Extended Warranty Desc.
Spectrum Brand	Standby	1 Year Industrial Standby Standard Warranty	
Standard Warranty Part #	Extended Warranty Part #		
GM50088			

Kits

Kit Type	Kit Material Number	Kit Description
Unknown	334531	LCB,2000A,3P,600V,UL,Elec
Unknown	299891	Power Factor Test,0.8,3Ph
Installed	GM28562-KA1S	Battery Charger,Float w/A
Installed	GM28379-MA5	Alternator,7M4050,Isolati
Unknown	272801	Generator Heater,120-240V
Installed	GM24329-MA1	Air Intake, Std. Duty
Installed	GM28625-KA27	Coolant in Genset 155 Gal
Installed	GM28464-KA1	Air Cleaner Restrict. Ind
Installed	GM30693-KA1	Flexible Fuel Lines
Unknown	333708	Voltage,60Hz,277/480V,Wye
Installed	GM19874-KA1	Decal, UL2200 Listing (Di
Installed	GM28377-MA1	Skid, Isolation Mount
Installed	GM28618-KA2	Controller Connection
Installed	GM28621-KA30	Oil in GenSet - 275 qts.
Installed	GM35181-MA3	Unit Mounted Radiator Coo
Unknown	279989	Nameplate Rating, Standby
Installed	GM28440-MA1S	Control & Harness, DDC Se
Installed	GM33830-KA3	Radiator Drain Valve
Installed	GM16993-MA8S	Controller,Digital550,24V
Installed	GM19408-KA2	Blk Htr,9000W,480V,1Ph w/

Unit Registrations

Serial #	Type	Submission ID	Service ID	Service Name	Owner Last Name	Owner Company	Registration Date
2027551	Original	0	10819	FLORIDA DD-A		UNIVISION NETWORK	03/26/2010