

Patten



AARON

46050001

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181

Customer Name: AARON
Unit Location: YARD
Unit #: 46050001
Manufacturer: GENERAC
Model #: PE4045D415478
Serial #: 4045DF150
Voltage Stability: GOOD
Rated KW: 35

Date: 5/21/2014
Work Order #:
Acct. #: 0
Tech #: 1511
Hour Meter Start: 10
Hour Meter Finish: 11

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.5	0.75	1	1.25	1.5	1.75	2
% of Load	101.0%	101.0%	101.0%	101.0%				
KW Meter	40.0	40.0	40.0	40.0				
Engine Speed	1,800	1,800	1,800	1,800				
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	240	240	240	240				
Voltmeter L2 - L3	240	240	240	240				
Voltmeter L1 - L3	N/A	N/A	N/A	N/A				
Ammeter L1	168	143	143	143				
Ammeter L2	67	144	144	143				
Ammeter L3	N/A	N/A	N/A	N/A				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	41	40	39	39				
Water Temp	181	182	183	183				
AMBIENT ROOM TEMP	65	65	65	65				
Exhaust Temp	N/A	N/A	N/A	N/A				
Oil Temp	N/A	N/A	N/A	N/A				
Battery Voltage	13.0	13.0	13.0	13.0				
Fuel Pressure	N/A	N/A	N/A	N/A				
Fuel Level	N/A	N/A	N/A	N/A				

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT FULL LOAD FOR 1 HR REPLACED RAIN CAP STUCK CLOSED. GEN CONTROL PANEL IS OUT OF CAL WILL NEED PROGRAM TO SET. UNIT HR METER NOT RUNNING UNIT HAS 10 HRS.

CUSTOMER SIGNATURE: _____

TECHNICIAN SIGNATURE: _____

Patten



AARON

46050001

LOAD AND OPERATION TEST

PAGE 2

**PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181**

Customer Name	AARON	Date	5/21/14
Unit Location	YARD	Work Order #	0
Unit #	46050001	Acct. #	0
Manufacturer	GENERAC	Tech #	1511
Model #	PE4045D415478	Hour Meter Start	10
Serial #	4045DF150	Hour Meter Finish	11
Voltage Stability	GOOD	0	0
Rated KW	35	0	0

MULTIPLE READING TEST

Elapsed Time Hrs.	9	10	11	12	13	14	15	16
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
LUBE OIL PRESSURE								
Water Temp								
AMBIENT ROOM TEMP								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								

COMMENTS AND RECOMMENDATIONS

RAN UNIT AT FULL LOAD FOR 1 HR REPLACED RAIN CAP STUCK CLOSED. GEN CONTROL PANEL IS OUT OF CAL WILL NEED PROGRAM TO SET. UNIT HR METER NOT RUNNING UNIT HAS 10 HRS.