

Unit

Serial Number	In-Service Date	Warranty Expiration	Sales Order Number
SGM322777	12/13/2012	12/13/2013	1010165644
Parts Coverage	Labor Coverage	Travel Coverage	
12 Months / 2000 Hours	12 Months / 2000 Hours	12 Months / 2000 Hours	
Model	Specification Number	Product ID	Material
300REZXB	GM78829-GA1	Generator Set	300REZXB
Test Date	Engine Serial Number	Engine Manufacturer Name	Engine Model
06/19/2012	EESOD200091	DOOSAN	D18.3L
Engine RPM	Fuel Type	KW	KVA
1800	Nat Gas	300	375.00
Amps	Power Factor	Hertz	Phase
451.00	0.80	60	
Low Volt	High Volt	Battery Volt	Market
277	480	24	Industrial
Brand	Usage	Standard Warranty Desc.	Extended Warranty Desc.
Kohler Generator Brand	Standby	1 Year Industrial Standby Standard Warranty	
Standard Warranty Part #	Extended Warranty Part #		
GM50088			

Kits

Kit Type	Kit Material Number	Kit Description
Installed	GM74764-KA1	Additional Gas Solenoid Valve
Installed	GM52294-KA1	LCB, 300A, LAP, Therm Mag, 80%
Installed	GM77563-KA1	Controller Connection
Installed	GM78511-KA5	MTG, LCB H-Frame 15-125A, H to L
Installed	GM78501-KA10	Panel, J-Box Closure
Installed	GM78831-MA1	Unit Mtd Radiator Cooling
Installed	GM74160-KA6	Block Heater, 6000W, 208V, 1Ph
Installed	GM79595-MA1	Skid & Mtg, 4M Alt
Installed	GM75495-KA1	Air Cleaner Restriction Indicator
Installed	GM80939-CA2	Breaker 2 Right Components
Installed	GM20747-KA1	Decal, UL2200 Listing (Gas)
Installed	GM78500-KA4	Panel, J-Box Barrier
Installed	GM75797-MA3	Controller, DEC550 Reconn
Installed	333708	Voltage,60Hz,277/480V,3Ph,4W,0.8PF
Installed	GM78503-KA1	Bracket, LCB Mounting
Installed	324588	Battery,2/12V,950CCA,Wet
Installed	GM80939-CA1	Breaker 1 Right Components
Installed	GM79596-MA1	Alternator & Mtg 4M4019
Installed	GM80939-CA3	Breaker 3 Right Components
Installed	GM71201-KA1	PreAlarm Sender
Installed	258811	Power Factor Test,0.8,3Ph Only
Installed	GM77563-KA5	Dry Contcts, 10SPDT, 10A
Installed	GM82664-KA2	Decal, Neutral (Unbonded)
Installed	GM78502-KA1	Bus, ABC Lead
Installed	222661	Nameplate Rating, Standby 130 Degree
Installed	GM78835-MA1	Control & Harness, Dec550
Installed	GM80939-CA9	Breaker Accessories (All Breakers)
Installed	GM79730-KA1	LCB, 60A, HDP, Therm Mag, 80%
Installed	GM80169-AA1	Send Master Track Ant Loose, Housed Unit

Installed	GM78500-KA1	Panel, J-Box Barrier
Installed	GM79059-KA2	Separator, LCB
Installed	GM80939-CA5	Breaker 1 Left Components
Installed	GM77563-KA4	Failure Relay Single Fault
Installed	358323	Fuel Code, Natural Gas
Installed	GM78512-KA1	MTG, LCB L-Frame 300-400A, L to L
Installed	GM52296-KA1	LCB, 400A, LAP, Therm Mag, 80%
Installed	GM77563-KA2	Run Relay, 24V
Installed	GM75926-KA1	Neutral
Installed	GM28625-KA12	Coolant in Genset 49 gals.
Installed	GM78501-KA1	Panel, J-Box Closure

Unit Registrations

Serial #	Type	Submission ID	Service ID	Service Name	Owner Last Name	Owner Company	Registration Date
SGM3227 77	Original	R13006872	13225	BAY CITY EQUIPMENT INDUSTRIES INC		World Trade Center Housing	03/09/2013

Claims

Claim Number	Claim Type	Shipment Type	Reference Number	Creation Date
--------------	------------	---------------	------------------	---------------

Unit Updates

Unit Update ID	Serial Number	Name	Description	Creation Date
----------------	---------------	------	-------------	---------------