

Patten



0

0

LOAD AND OPERATION TEST

PAGE 1

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE: (877) 891-4181 www.pattenpower.com

1

Customer Name:	0	Date:	06/18/15
Unit Location:	0	Work Order #:	0
Unit #:	0	Acct. #:	
Manufacturer:	CAT	Tech #	1511
Model #:	3412	Hour Meter Start	21594
Serial #:	02WJ02645	Hour Meter Finish	21,595.0
Voltage Stability	GOOD	Package Serial #:	0
Rated KW	725		

MULTIPLE READING TEST

Elapsed Time Hrs.	0.25	0.50	0.75	1.00	1.25	1.50	1.75	2.00
% of Load	59.4%	59.4%	103.1%	103.1%	0.0%	0.0%	0.0%	0.0%
KW Meter	430.8	430.8	747.8	747.2	0.0	0.0	0.0	0.0
Engine Speed	1,800	1,800	1,800	1,800	0	0	0	0
Power Factor	1.00	1.00	1.00	1.00				
Voltmeter L1 - L2	483	483	482	482				
Voltmeter L2 - L3	483	483	482	482				
Voltmeter L1 - L3	482	482	481	481				
Ammeter L1	516	516	896	896				
Ammeter L2	514	514	897	896				
Ammeter L3	516	516	896	895				
Frequency Meter	60.0	60.0	60.0	60.0				
Lube Oil Pressure	76	72	70	68				
Water Temp	178	180	190	192				
Ambient Room Temp	67	67	68	68				
Exhaust Temp	650	680	980	1050				
Oil Temp	n/a	n/a	n/a	n/a				
Battery Voltage	27.0	27.0	27.0	27.0				
Fuel Pressure	39	39	36	36				
Fuel Level	full	full	full	full				

COMMENTS AND RECOMMENDATIONS

CUSTOMER SIGNATURE: _____ Date: June 18, 2015

TECHNICIAN SIGNATURE: _____ Date: June 18, 2015

Patten



0

0

LOAD AND OPERATION TEST

PAGE 2

PATTEN POWER SYSTEMS 24 HOUR CENTRAL DISPATCH EMERGENCY TELEPHONE TOLL FREE:
1 (877) 891-4181 www.pattenpower.com

Customer Name	0	Date	6/18/15
Unit Location	0	Work Order #	0
Unit #	0	Acct. #	0
Manufacturer	CAT	Tech #	1511
Model #	3412	Hour Meter Start	21594
Serial #	02WJ02645	Hour Meter Finish	21,595.0
Voltage Stability	GOOD	Package Serial #:	0
Rated KW	725		0

MULTIPLE READING TEST

Elapsed Time Hrs.	2.25	2.50	2.75	3.00	3.25	3.50	3.75	4.00
% of Load	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
KW Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Engine Speed	0	0	0	0	0	0	0	0
Power Factor								
Voltmeter L1 - L2								
Voltmeter L2 - L3								
Voltmeter L1 - L3								
Ammeter L1								
Ammeter L2								
Ammeter L3								
Frequency Meter								
Lube Oil Pressure								
Water Temp								
Ambient Room Temp								
Exhaust Temp								
Oil Temp								
Battery Voltage								
Fuel Pressure								
Fuel Level								
0								
0								
0								

COMMENTS AND RECOMMENDATIONS

0

CUSTOMER SIGNATURE: _____ Date: June 18, 2015

TECHNICIAN SIGNATURE: _____ Date: June 18, 2015