



LOAD
BANK TEST

ENGINE DIVISION
1-800-833-1789

CUSTOMER NO.	CUSTOMER NAME				W.O. # 4896015	
GENERATOR SET LOCATION Novi		UNIT NO. N/A	CONTACT			TELEPHONE NO.
ENGINE MODEL G3516		SERIAL NO. 3RC00579			SERVICE METER 167	DATE 2/10/2015
GENERATOR MODEL		SERIAL NO.		KW RATING 800	VOLTS	SERVICE LEVEL 1

			VOLTS			AMPS					
TIME	Hz	KW	A	B	C	A	B	C	OIL PRESS	COOLANT TEMP	AMBIENT TEMP
0	60	756	485	485	485	901	902	898	60	180	0
0.5	60	757	485	485	485	901	902	897	60	180	0
1	60	757	485	485	485	900	904	895	60	180	0
1.5											
2											
2.5											
3											
3.5											
4											
4.5		0									
5		0									
5.5		0									
6		0									
6.5		0									
7		0									
7.5		0									
8		0									

COMMENTS, RECOMMENDATIONS

SERVICE TECHNICIAN	DATE	CUSTOMER REPRESENTATIVE	DATE
--------------------	------	-------------------------	------

[illegible]