

Unit

Serial Number	In-Service Date	Warranty Expiration	Sales Order Number
277276	05/08/1991	05/08/1996	T00910
Parts Coverage	Labor Coverage	Travel Coverage	
60 Months / 3000 Hours	60 Months / 3000 Hours	60 Months / 3000 Hours	
Model	Specification Number	Product ID	Material
100ROZJ	189601	Generator Set	100ROZJ81
Test Date	Engine Serial Number	Engine Manufacturer Name	Engine Model
02/28/1991	337882	JOHN DEERE	
Engine RPM	Fuel Type	KW	KVA
0		100	125.00
Amps	Power Factor	Hertz	Phase
347.00	0.80	60	
Low Volt	High Volt	Battery Volt	Market
120	208	12	Industrial
Brand	Usage	Standard Warranty Desc.	Extended Warranty Desc.
Kohler Generator Brand	Standby	1 Year Industrial Standby Standard Warranty	5 Year Industrial Extended Comprehensive Warranty
Standard Warranty Part #	Extended Warranty Part #		
GM50088	221886-F		

Kits

Kit Type	Kit Material Number	Kit Description
Unknown	275585	KIT, BLOCK HTR 110-120
Unknown	273605	KIT, SILENCER MTNG C&I
Unknown	253615	KIT, SILENCER - CRITICAL
Unknown	255130	KIT, SAFEGUARD BREAKER
Unknown	273402	KIT, RAD DUCT FLG 105,125
Unknown	254481	KIT, WEATHER HOUSING
Unknown	273642	KIT, BATTERY RACK

Unit Registrations

Serial #	Type	Submission ID	Service ID	Service Name	Owner Last Name	Owner Company	Registration Date
277276	Original	0	15573	ZZZ - DEFAULT CUSTOMER		VENCOR HOSPITAL	03/26/2010

Claims

Claim Number	Claim Type	Shipment Type	Reference Number	Creation Date
--------------	------------	---------------	------------------	---------------

Unit Updates

Unit Update ID	Serial Number	Name	Description	Creation Date
----------------	---------------	------	-------------	---------------