

TO	TYPE	LOCATION	CO ₂ COMP.	PROCESS "A"	PROCESS "B"	MCC	PLANT
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5
120 VAC	4 TO 20 MA	RTD	7-C	10-C	2-C	50-5	22-5

FIELD WIRING SUMMARY FROM NH₃ PANEL
FROM THIS PANEL
AS THE CONTROL PANEL IS LOCATED ON THE NH₃ COMPRESSION SKID, ALL WIRES ARE DISTRIBUTED

PLANT LOCATION REPRESENTS ALL REMAINING AREAS NOT LISTED IN SUMMARY. CHECK WIRE COUNT SHEETS FOR A MORE ACCURATE LOCATION
5 - SINGLE CONDUCTOR - 120 VAC SERVICE
CHECK ON WIRE COUNT SHEETS FOR HIGH VOLTAGE DEVICE WIRING
NOTE 1-4 CONDUCTOR SHIELDED CABLE IS TO BE RUN FROM THE NH₃ CONTROL PANEL TO THE AREA IN WHICH THE ITEM IS LOCATED
COMPUTER IS TO BE LOCATED

THE INFORMATION CONTAINED HEREIN IS THE CONFIDENTIAL PROPERTY OF CANADIAN LIQUID AIR LTD. / COURTESY CO₂ PLANT
NOV. 26, 1985
A-25511
A-25511-2

NOTE: F.O.F AND ELEVATIONS FOR PIPES & NOZZLES ARE FROM A TOP OF STEEL DATUM
SKID DEPTH IS 1'-0 1/4"

REV	DESCRIPTION	DATE	BY
0	ISSUED FOR APPROVAL		
1	ISSUED FOR CONSTRUCTION	11/18/85	THOMAS WAH
2	GENERAL REVISIONS	11/18/85	THOMAS WAH
3	GENERAL REVISIONS	11/18/85	THOMAS WAH
4	ADDED NH ₃ LIQUID PUMPS	11/18/85	THOMAS WAH
5	ADDED NH ₃ LIQUID PUMPS	11/18/85	THOMAS WAH
6	AS BUILT	11/18/85	THOMAS WAH

